INSTALLATION INSTRUCTIONS

700, 700E, 9700 Series

Perimeter Seals

700EN, 700ES, 700N, 700S, 706E, 9700

POSITIVE PRESSURE TESTED GASKETING MATERIALS FOR FIRE DOORS FOR APPLICATION TO HOLLOW-METAL-TYPE FIRE DOORS RATED UP TO 3 HOURS AND WOOD-TYPE FIRE DOORS RATED UP TO 1½ HOURS. CATEGORY H

SMOKE AND DRAFT CONTROL GASKETING (CATEGORY H) TESTED TO UL 1784; MEETS REQUIREMENTS OF NFPA 105, IBC FOR USE ON "S" LABEL DOORS. APPLIES TO 700EN, 700N, 700ES, 700S, 706E, 9700, ONLY.

700EU, 700U, 705EV, 705V

POSITIVE PRESSURE TESTED GASKETING MATERIALS FOR FIRE DOORS FOR APPLICATION TO HOLLOW-METAL-TYPE FIRE DOORS RATED UP TO 3 HOURS AND WOOD-TYPE FIRE DOORS RATED UP TO 1½ HOURS. CATEGORY J

ngp.com
1-800-NGP-RUSH
FAX: (800) 255-7874
QUOTES: quotes@ngp.com
ORDERS: orders@ngp.com

INSTALLATION INSTRUCTIONS

IMPORTANT NOTE:
Install seals before the closer. Seals installed at head will require the closer body be installed 1/4" lower on the door.

1. Cut seal to fit.
2. Drill head piece for mounting screws, avoiding the area where the closer shoe will be located.
3. With door closed, position seal with the gasketing slightly compressed against the door.
4. Install with TEK screws provided, working from one end to the other.

ngp.com
1-800-NGP-RUSH

FAX: (800) 255-7874
QUOTES: quotes@ngp.com
ORDERS: orders@ngp.com

NGP MEMPHIS
4985 East Raines Road
Memphis, TN 38118

CARSON CITY
3689 Arrowhead Drive
Carson City, NV 89706